



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/18 Pt.1 T/J(249)

23 March 2018

[Faint, illegible text, likely bleed-through from the reverse side of the page]

Approval of “JAMES” Check Valves

Your letter dated 28 February 2018 and subsequent submission received by this department on 12 March 2018 refer.

Having considered the test report ref. BC-SUMMARY-2016-106 issued on 16 December 2016 by Castco Testing Centre Ltd. and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:	Hoi Luen Hardware Co Ltd
Country of Origin:	China
Brand:	James
Details of Fittings:	Ductile iron wafer type silent check valve with epoxy coating under WRAS approval no. 1603543
Model:	WSCM
Size:	50mm, 65mm, 80mm, 100mm, 150mm

Body Markings: PN16 GGG40

Expiry Date: 31 March 2021

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



WSCM