

FUGRO TECHNICAL SERVICES LIMITED

Fugro Development Centre 5 Lok Yi Street, Tai Lam Tuen Mun, NT Hong Kong

Client Ref. : --

Report No. : 252499PC250775

Page 1 of 2

REPORT ON TESTING OF AIR RELEASE VALVE

Information Supplied by Client

Client : Hoi Luen Hardware Company Limited

Client Address : Shop A, G/F, King Centre, 23 Dundas Street, Mong Kok, Kowloon

Project : Testing of Air Release Valve

Sample Description : Brass Automatic Air Release Valve (AIR Vent)

Brand : JAMES

Body Marking JAMES

Model No. : 5301 Country of Origin : China

Manufacturer : Hoi Luen Hardware Company Limited

Laboratory Information

Lab. Sample I.D. : PC250775/1-3

Date Received : 14 July 2025
Date Test Started : 21 July 2025
Date Test Completed : 28 July 2025

Test Method : BS EN 12266-1 : 2012

Test Results

1. Pressure Test

(BS EN 12266-1: 2012)

Lab Sample I.D.	Nominal Size (Inch)	Shell Test				
		Nominal Pressure PN (bar)	Test Pressure (bar)	Duration (sec)	Observation	Results
PC250775/1	15mm (1/2")	16	24	15	No visually detectable leakage	Pass
PC250775/2	20mm (3/4")	16	24 •	15	No visually detectable leakage	Pass
PC250775/3	25mm (1")	16	24	15	No visually detectable leakage	Pass
BS EN 12266-1 : 2012 Annex A.3 Requirement		16	-16x1.5 =24	Up to DN50 (min.15 sec)	Visually detectable leakage is not permitted	

Remark: The report refers only to the sample(s) tested and the result(s) applied to the sample(s)

as received.

Checked by :

Date: 19 AUG 2025

Certified by :

Date:

1 9 AUG 2025

Ng Shu Shing Chris

Assistant Manager (Plumbing Components)





Fugro Development Centre 5 Lok Yi Street, Tai Lam Tuen Mun, NT Hong Kong

Client Ref. : -

Report No. : 252499PC250775





Test Sample (1/2")



Test Sample (3/4")



Test Sample (1")

End of Report